

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: FS Curtis		
	Model Number: NxB18-175	Date:	4/23/2015
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	83.8	acfm ^{a,e}
4*	Full Load Operating Pressure b	175	psig
5	Maximum Full Flow Operating Pressure c	175	psig ^c
6	Drive Motor Nominal Rating	25	hp
7	Drive Motor Nominal Efficiency	93.6	percent
8	Fan Motor Nominal Rating (if applicable)	1	hp
9	Fan Motor Nominal Efficiency	82.5	percent
10*	Total Package Input Power at Zero Flow ^e	6.8	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	23.36	kW ^d
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	27.88	kW/100 cfm ^e
13	Isentropic Efficiency	64.23	Percent

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate Specific Energy Zero Flow at specified conditions Volume Flow Rate Power Consumption % ft³ / min % % \underline{m}^3 / \min Below 0.5 Below 17.6 +/- 7 +/- 8 17.6 to 53 0.5 to 1.5 +/- 7 +/- 6 +/- 10% 1.5 to 15 53 to 529.7 +/- 5 +/- 6 Above 529.7 +/- 4 +/- 5 Above 15



Member

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.