	RTIS I	n Accor	dance with Fe	COMPRESSOR DATA SHE deral Uniform Test Method for Cert	ain Lubricated Air	Compressors	
				Rotary Compressor: Fixed Sp			
	MODEL DATA - FOR COMPRESSED AIR						
	1	Manufacturer: FS Curtis					
		Model Number: NxB30-175			Date:	4/23/2015	
	2	X	Air-cooled	Water-cooled	Type:	Screw	
					# of Stages:	1	
	3*	Rated Capacity at Full Load Operating Pressure ^{a, e}			149.1	acfm ^{a,e}	
	4*		d Operating Pres	h	175	psig ^b	
	5	Maximu	am Full Flow Operating Pressure c		175	psig ^c	
	6		lotor Nominal Ra		40	hp	
	7	Drive M	lotor Nominal Ef	iciency	94.1		
			tor Nominal Ratin	•	1	percent	
	8		tor Nominal Effic		87.5	hp	-
	9			-	per	e	
	10*		ickage Input Pow	er at Zero Flow er at Rated Capacity and Full Load		kW ^e	
	11	Operating Pressure ^d			38.80	kW^d	
	12*	Package Pressure		at Rated Capacity and Full Load Operating	26.02	kW/100 cfm ^e	
	13	Isentrop	ic Efficiency		68.80	Percent	
	*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.						l .
NOTES: a. b. CACI c. d.			site for a list of participants in the third party verification program: www.cagi.org Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power. Total package input power at other than reported operating points will vary with control strategy. Tolerance is specified in ISO 1217, Annex C, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.				
			Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
Memb	Member		m ³ / min	ft^3 / min	%	%	%
			Below 0.5	Below 17.6	+/- 7	+/- 8	
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
			1.5 to 15	53 to 529.7	+/- 5	+/- 6	10/0
ROT 030.1			Above 15	Above 529.7	+/- 4	+/- 5	
12/19 Rev 3	This form w	as developed	l by the Compressed Air	and Gas Institute for the use of its members participating in	the PVP. CAGI has not independ	lently verified the reported data.	