

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: FS Curtis		
	Model Number: NxHE132A-150	Date:	6/19/2018
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	2
3*	Rated Capacity at Full Load Operating Pressure a, e	793.6	acfm <sup>a,e</sup>
4*	Full Load Operating Pressure b	150	psig b
5	Maximum Full Flow Operating Pressure <sup>c</sup>	151	psig c
6	Drive Motor Nominal Rating	180	hp
7	Drive Motor Nominal Efficiency	96.2	percent
8	Fan Motor Nominal Rating (if applicable)	5.5	hp
9	Fan Motor Nominal Efficiency	89.5	percent
10*	Total Package Input Power at Zero Flow <sup>e</sup>	64.9	kW <sup>e</sup>
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	156.2	$kW^d$
12*	Package Specific Power at Rated Capacity and Full Load Operating  Pressure e	19.7	kW/100 cfm <sup>e</sup>
13	Isentropic Efficiency	84.04	Percent

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate Specific Energy Zero Flow at specified conditions Volume Flow Rate Power Consumption % ft<sup>3</sup> / min % %  $\underline{m}^3 / \min$ Below 0.5 Below 17.6 +/- 7 +/- 8 17.6 to 53 0.5 to 1.5 +/- 7 +/- 6 +/- 10% 1.5 to 15 53 to 529.7 +/- 5 +/- 6 Above 529.7 +/- 4 +/- 5 Above 15

Compressed Air & Gas Institute

Member

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.