	TIS I	n Accordance with Fe	COMPRESSOR DATA SHE deral Uniform Test Method for Cert	ain Lubricated Air	Compressors	
Г			Rotary Compressor: Fixed Sp MODEL DATA - FOR COMPRES			7
	1	Manufacturer:	FS Curtis			
		Model Number:	Model Number: NxHE160A-125		6/19/2018	_
2		X Air-cooled	Water-cooled	Туре:	Screw	
				# of Stages:	2	
	3*	Rated Capacity at Full Lo	oad Operating Pressure ^{a, e}	1074.7	acfm ^{a,e}	
F	4*	Full Load Operating Pres	h	125	psig ^b	
	•			125	psig ^c	
	5 Maximum Full Flow Operating Pressure c 6 Drive Motor Nominal Rating 7 Drive Motor Nominal Efficiency					_
				220	hp	
_				96.2	percent	
	8		Nominal Rating (if applicable)		hp	
	9	Fan Motor Nominal Effic	-	91	percent	
	10*			78.4	kW ^e	
	11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d		187.8	kW^d	
	12*		at Rated Capacity and Full Load Operating	17.5	kW/100 cfm ^e	
Ē	13	Isentropic Efficiency		85.95	Percent	1
CAG	Consult C NOTES:	 AGI website for a list of particle a. Measured at the disclession of th	Performance Verification Program, these items are re- tipants in the third party verification program: harge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions. re at which the Capacity (Item 3) and Electrical Consump tainable at full flow, usually the unload pressure setting is tainable before capacity control begins. May require ad yower at other than reported operating points will vary we in ISO 1217, Annex C, as shown in table below: nower" and "energy" are synonymous for purposes of this	<u>www.cagi.org</u> lance with otion (Item 11) were measured for load/no load control or the ditional power. ith control strategy.	lministrator.	
Compressed Air & Gas Institute			Volume Flow Rate		Specific Energy	Zero Flov
Member		m ³ / min	at specified conditions ft ³ / min	Volume Flow Rate %	Consumption %	Power %
	-	Below 0.5	Below 17.6	+/- 7	+/- 8	
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
T 030.1		1.5 to 15 Above 15	53 to 529.7 Above 529.7	+/- 5 +/- 4	+/- 6 +/- 5	
		L		II_		1