

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacture	er: FS Curtis				
2	Model Number: NxV08-100				Date:	September, 2015
	X Air-cooled Water-cooled				Type:	Screw
					# of Stages:	1
3*	Full Load O	perating Pressure ^b	100	psig ^b		
4	Drive Motor	Drive Motor Nominal Rating		10	hp	
5	Drive Motor Nominal Efficiency		87.7	percent		
6	Fan Motor Nominal Rating (if applicable)		n/a	hp		
7	Fan Motor N	Fan Motor Nominal Efficiency		n/a	percent	
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	9.6			45.98	20.88	
	8.5			40.22	21.13	
	7.3			34.56	21.12	
	6.3			28.63	22.00	
	4.0		16.96	23.58		
9*	Total Package Input Power at Zero Flow c, d			0.0		kW
10	Isentropic E	sentropic Efficiency		60.90	%	
11	Specific Power (Minition ACTWA)	20.00		30.00 Capacity (ACFM)	40.00	50.00
		Note: Y-A	xis Scale, 10 to 35, - X-Axis Scale, (e Verification P	sual representation of the data in S + 5kW/100acfm increments if necess 0 to 25% over maximum capacity rogram, these items are ver rification program:	ary above 35	l party administrator



c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member U LUA Zero Flow Volume Flow Rate Specific Energy at specified conditions Volume Flow Rate Consumption Power % m³ / min $\underline{ft}^3 / \underline{min}$ % % Below Below 17.6 +/- 7 +/- 8 0.5 0.5 to 1.5 17.6 to 53 +/- 6 +/- 7 +/- 10% 53 to 529.7 1.5 to 15 +/- 5 +/- 6 Above 529.7 +/- 5 Above 15 +/- 4 ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.