

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL DA	ATA	- FOR	COM	PRESS	ED AIR				
1	Manufacture	:: FS Cu	ırtis									
	Model Number: NxV15-100							Date	e: Se	ptember, 2015		
2	X Air-cooled Water-cooled					,		Туре	e:	Screw		
								# of Stages	s:	1		
3*	Full Load Operating Pressure					1	00		b psig ^b			
4		Drive Motor Nominal Rating					0		hp			
5	Drive Motor Nominal Efficiency					88	3.7		percent			
6	Fan Motor Nominal Rating (if applicable)					n	/a		hp			
7	Fan Motor No	ominal Effici	ency			n	/a		percent			
	Input Power (kW)			(Capacity	(acfm) ^{a,}	d	Specific Power (kW/100 acfm) ^d				
	17.5					84	.25		20.77			
8*	15					74	.48		20.14			
	13.1				64	.32		20.37				
	11.6				53	.96		21.50				
	7.6				3	2		23.75				
9*	Total Package Input Power at Zero Flow c, d				c, a	0	.0		kW			
10	Isentropic Efficiency					62	.00			%		
11	Specific Power (kW/100 ACEM)	35.00 30.00 25.00 20.00 10.00	20.00	30.00	40.00 Capa	50.00 city (ACFM	60.00	70.00 80.00	90.00	100.00		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.