

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL DATA	- FOR (COMP	RESSED	AIR			
1	Manufacturer:	FS Cu	rtis							
	Model Number: NxV15-175							Septe	ember, 2015	
2	X Air-cooled Water-cooled				Туре			Screw		
						:	# of Stages:		1	
3*	Full Load Oper	Full Load Operating Pressure				5	psig ^b			
4		Drive Motor Nominal Rating)	hp			
5	Drive Motor Nominal Efficiency				88	.7	percent			
6	Fan Motor Nominal Rating (if applicable)				n/	a	hp			
7	Fan Motor Nor	Fan Motor Nominal Efficiency				a	percent			
	Input Power (kW)			Ca	apacity	(acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	18				64.	94	27.72			
8*	15.7				5	7	27.54			
	14				48.	89	28.64			
	12.4				40.	37	30.72			
	10.7			o d	31.	67		33.79		
9*	Total Package Input Power at Zero Flow c, d				0.			kW		
10	Isentropic Effic	Isentropic Efficiency				90			%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 10.00 N	Note: Graph is on ote: Y-Axis Scale, 10	Capaci	100acfm inc	rements if neces	60.00 Section 8 sary above 35	70.00	80.00	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.