

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DATA -	FOR COMPRESSI	ED AIR		
1	Manufacturer:	FS Cu	rtis				
	Model Number	: NxV1	50-100		Date:	March, 2018	
2	X Air-cooled Water-cooled				Type:	Screw	
					# of Stages:		
3*	Full Load Operating Pressure b			100		psig	
4		Drive Motor Nominal Rating				hp	
5	Drive Motor Nominal Efficiency			96.2		percent	
6	Fan Motor Nominal Rating (if applicable)			6		hp	
7	Fan Motor Nominal Efficiency			89.5		percent	
	Input Power (kW)			Capacity (acfm) <sup>a,c</sup>	1	Specific Power (kW/100 acfm) <sup>d</sup>	
	211			1030		20.49	
8*	177			903		19.60	
	150			768		19.53	
	120			618		19.42	
	64			340 <b>0.0</b>		18.82	
9*		Total Package Input Power at Zero Flow c, d				kW	
10	Isentropic Effic	Isentropic Efficiency				%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 10.00 0.0 80.	Note: Graph is only ote: Y-Axis Scale, 10 to	0 400.0 480.0 560.0 640.0 Capacity (ACFM) a visual representation of the data 35, + SkW/100acfm increments if neale, 0 to 25% over maximum capacit	in Section 8 excessary above 35	960.0 1,040.0 1,120.0	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.