

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: FS Curtis						
	Model Number: NxV18-100		Date:	June, 2015			
2	X Air-cooled Water-coole	ed	Type:	Screw			
		:	# of Stages:	1			
3*	Full Load Operating Pressure b	Operating Pressure b 100		psig <sup>b</sup>			
4	Drive Motor Nominal Rating	25		hp			
5	Drive Motor Nominal Efficiency	88.5		percent			
6	Fan Motor Nominal Rating (if applicab	le) 1	hp				
7	Fan Motor Nominal Efficiency	82.5		percent			
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	22.3	112	19.91				
8*	19.1	96.8		19.73			
	16.1	81.4	19.78				
	13.3	65.4	20.34				
	7.1	33.4 c, d	21.26				
9*	Total Package Input Power at Zero Flov	v 0.0	kW				
10	Isentropic Efficiency	65.80	%				
11	Note: Y-Axis Scale,	50.00 75.00  Capacity (ACFM)  only a visual representation of the data in 10 to 35, + 5kW/100acfm increments if neces xis Scale, 0 to 25% over maximum capacity	100.00 Section 8 sary above 35	) 125.00			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.