

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL D	ATA - I	OR CO	OMPRI	ESSED A	AIR			
1	Manufacturer	: FS Cu	ırtis								
	Model Number: NxV30-100							Date:	SEPTE	MBER, 2019	
2	Air-cooled Water-cooled							Type:		Screw	
							# (of Stages:		1	
3*	Full Load Operating Pressure					100		psig			
4		Drive Motor Nominal Rating				40		hp			
5	Drive Motor Nominal Efficiency					93		percent			
6	Fan Motor Nominal Rating (if applicable)					1.5		hp			
7	Fan Motor No	ominal Effici	ency			87.5			percent		
8*	Input Power (kW)			Capa	acity (acf	m) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	37.3					190		-	19.63		
	31.3					165		18.97			
		25.8				136			18.97		
	19.8				103			19.22			
		11.9 60					19.83				
9*	Total Package Input Power at Zero Flow c, d					0.0			kW		
10	Isentropic Eff	ficiency				68.90				%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 0.00	25.00	50.00	75.00 Capacity (100.00 ACFM)	125.00	150.00	175.00	200.00	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.