

## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MOI	DEL DATA ·	- FOR	COMPRESSI	ED AIR		
1	Manufacturer:	FS Cu	rtis					
	Model Number: NxV37-125					Date:	SEPTEMBER, 2015	
2	X Air-cooled Water-cooled				Туре:		Screw	
						# of Stages:	1	
3*	Full Load Operating Pressure <sup>b</sup>				125		psig	
4	Drive Motor Nominal Rating				50		hp	
5	Drive Motor Nominal Efficiency				89.5		percent	
6	Fan Motor Nominal Rating (if applicable)				1.5		hp	
7	Fan Motor Nominal Efficiency				87.5		percent	
	Input Power (kW)			C	Capacity (acfm) <sup>a,c</sup>		Specific Power (kW/100 acfm) <sup>d</sup>	
	48.3				210.3		22.97	
8*	42.1				183.4		22.96	
	29.6				133		22.26	
	23.5				104.7		22.45	
	13			ı d	50.9		25.54	
9*	Total Package Input Power at Zero Flow c, d			, u	0.0		kW	
10	Isentropic Effic	Isentropic Efficiency			66.10		%	
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 10.00	ote: Y-Axis Scale, 10 t	y a visual r to 35, + 5kV	100.00 125.00 city (ACFM) epresentation of the data '/100acfm increments if ne 5% over maximum capacit	cessary above 35	200.00 225.00	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.