

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL D	ATA - F	OR CO	OMPRE	SSED A	AIR				
1	Manufacturer:	FS Cu	rtis									
	Model Number: NxV37-150							Date:	SEPTEMBER, 2015			
2	X Air-cooled Water-cooled					Type:			Screw			
							# (of Stages:		1		
3*	Full Load Ope	l Load Operating Pressure						psig ^b				
4		Drive Motor Nominal Rating						hp				
5	Drive Motor N	Drive Motor Nominal Efficiency				89.5			percent			
6	Fan Motor Nominal Rating (if applicable)					1.5		hp				
7	Fan Motor No	Motor Nominal Efficiency				87.5			percent			
8*	Input Power (kW)			Capa	acity (acf	m) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	46.3					189.2		24.47				
	40.9					168.3		24.30				
	30.2				124		24.35					
	24.7				100.2		24.65					
	14.4				49.7		28.97					
9*	Total Package	Total Package Input Power at Zero Flow c, d				0.0			kW			
10	Isentropic Effi	sentropic Efficiency				67.00				%		
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00	25.00 Note: G	50.00 Fraph is only a Scale, 10 to 3: X-Axis Scal	5 + 5 kW / 100	sentation of the	nts if necessary	150.00 ion 8 v above 35	175.00	200.00		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.