



## COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

### Rotary Compressor: Variable Frequency Drive

#### MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer: <b>FS Curtis</b>		
2	Model Number: <b>NxV55-125</b>		Date: <b>APRIL, 2016</b>
	<input checked="" type="checkbox"/> Air-cooled	<input type="checkbox"/> Water-cooled	Type: <b>Screw</b>
			# of Stages: <b>1</b>
3*	Full Load Operating Pressure <sup>b</sup>	<b>125</b>	psig <sup>b</sup>
4	Drive Motor Nominal Rating	<b>75</b>	hp
5	Drive Motor Nominal Efficiency	<b>95</b>	percent
6	Fan Motor Nominal Rating (if applicable)	<b>2</b>	hp
7	Fan Motor Nominal Efficiency	<b>86.5</b>	percent
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	71.8	314.2	<b>22.85</b>
	61.3	268	<b>22.87</b>
	50.7	219.4	<b>23.11</b>
	40.5	170.7	<b>23.73</b>
9*	26.7	94	<b>28.40</b>
	Total Package Input Power at Zero Flow <sup>c, d</sup>		<b>0.0</b> kW
10	Isentropic Efficiency	<b>63.70</b>	%
11	<div style="text-align: center;"> <p style="font-size: small; margin-top: 5px;"> <b>Note: Graph is only a visual representation of the data in Section 8</b>                      Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35                      X-Axis Scale, 0 to 25% over maximum capacity                 </p> </div>		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: [www.cagi.org](http://www.cagi.org)



Member

- NOTES:
- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
  - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1