

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MO	DEL DATA - FO	OR COMPRESSED	AIR			
1	Manufacturer:	FS Cu	rtis					
	Model Number	r: NxV7	5-125		Date:			
2	X Air-cooled Water-cooled			Type:		Screw		
				#	of Stages:	1		
3*	Full Load Operating Pressure			125		psig		
4	Drive Motor Nominal Rating			100	hp			
5	Drive Motor Nominal Efficiency			95.4	percent			
6	Fan Motor Nominal Rating (if applicable)			3	hp			
7	Fan Motor Nor	minal Effici	ency	89.5		percent		
	Input Power (kW)			a.d		Specific Power (kW/100 acfm) ^d		
	99.5			450.8	22.07			
8*	85			388.4	21.88			
	72			326.6	22.05			
	58.9			258.9	22.75			
	32.2			119.7	26.90			
9*	Total Package		r at Zero Flow c, d	0.0		kW		
10	Isentropic Efficiency			66.30		%		
11	Specific Power (RW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 35.00	Note: Graph is only a vis	5.00 210.00 245.00 280.00 315.00 Capacity (ACFM) ual representation of the data in St. 5.5W/100acfm increments if necesses	ection 8	420.00 455.00 490.00		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.