

## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DATA - FO	OR COMPRESSED	AIR			
1	Manufacturer:	FS Cu	rtis					
	Model Numbe	r: NxV9	0-100		Date:			
2	X Air-cooled Water-cooled			Type:		Screw		
				#	of Stages:	1		
3*	Full Load Operating Pressure b			100	psig			
4		Drive Motor Nominal Rating			hp			
5	Drive Motor Nominal Efficiency			95.4	percent			
6	Fan Motor Nominal Rating (if applicable)			3	hp			
7	Fan Motor No	minal Effici	ency	89.5		percent		
8*	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	121			567.3	21.33			
	98.8			483	20.46			
	78.4			388.2	20.20			
		59.4			19.90			
	26.6			120.7	22.04			
9*		Total Package Input Power at Zero Flow				kW		
10	Isentropic Efficiency			65.20		%		
11	Specific Power (KW/100 ACFA)	35.00 30.00 25.00 20.00 15.00 10.00 0.0 40.	(	.0. 240.0 280.0 320.0 360.0 400  Capacity (ACFM) sual representation of the data in St. + SkW/100acfm increments if necessar	ection 8	520.0 560.0 600.0		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
   NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.